

Danish Indoor Climate Labelling

Certificate no. 047



Danish Indoor Climate Labelling hereby certifies that the product group:

REHAU Window Profiles

REHAU A/S
Industrivej 51A
4000 Roskilde
Denmark

has been approved and awarded a labelling license

The labelling license is valid through:

11 October 2026

Danish Indoor Climate Labelling

*This certificate is subject to annual renewal according to the procedures of Danish Indoor Climate Labelling.
Danish Indoor Climate Labelling may withdraw the rights to use this certificate in case the manufacturer does not meet the requirements.*

Danish Indoor Climate Labelling

Certificate no. 047

Labelling license holder:

REHAU A/S
Industrivej 51A
4000 Roskilde
Denmark

Product group
Testing and labelling criteria

REHAU Window Profiles
General labelling criteria, 7th edition, 2021
Windows and exterior doors, 4th edition, 2018

Date of first issue of license
Tested product(s)

11 October 2002
RAU-FIBRO Window profile

Evaluation of product group

EMISSION CLASS 1

The labelling license covers products considered to be identical with the tested product regarding emission and particle characteristics as specified by the labelling criteria. For a full list of products covered by the labelling license, see Appendix.

The emission class was determined based on the following measured values:

Emission measured after 28 days		
TVOC ₂₈	< 0,005	mg/m ³
Formaldehyde ₂₈	< 0,005	mg/m ³

Sensory evaluation	
Time-value	10 days

Labelling license basis

The tested product(s) shows compliance with the DICL criteria for the present product group:

Emission measured after 3 days		
TVOC	≤	10 mg/m ³
EU CARC 1A and 1B	≤	0.01 mg/m ³

Emission measured after 28 days		
Sum of TVOC and SVOC with LCI	≤	1.0 mg/m ³
EU CARC 1A and 1B	≤	0.001 mg/m ³
R-value	≤	1

Sensory evaluation		
Time-value	≤	30 days

Emission Class 1	TVOC ₂₈	≤	0.5	mg/m ³
	Formaldehyde ₂₈	≤	0.01	mg/m ³
Emission Class 2	TVOC ₂₈	≤	1.0	mg/m ³
	Formaldehyde ₂₈	≤	0.06	mg/m ³
Emission Class 3	TVOC ₂₈	≤	1.0	mg/m ³
	Formaldehyde ₂₈	≤	0.1	mg/m ³

Product information requirements

The holder of the labelling license is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor air quality in practice: product specifications, guidelines for transport, storage, assembly, cleaning and maintenance.

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.